



**DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES**

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

September 2, 2026

Jim Housiaux, P.E.
Stockwell Engineers, Inc.
801 N Phillips Avenue
Sioux Falls, SD 57104

RE: Evapotranspiration Wastewater System Approval – Miner County, South Dakota.
P&S 26-1126

Dear Mr. Housiaux:

The South Dakota Department of Agriculture and Natural Resources is in receipt of one set of plans and specifications for an evapotranspiration wastewater system that will service facilities for Buckeye Swine located at 43012 224th Street on Tract 1, Hord's Addition in the SW ¼ of Section 19, T108N, R56W, Miner County, South Dakota. The plans have been reviewed for compliance with South Dakota's "Individual and Small On-Site Wastewater Systems" regulations.

The results of the review process indicate the wastewater systems are designed for a maximum daily flow of 2,400 gallons. This design will meet the minimum design requirements and is hereby approved with the following conditions:

- A profile test hole shall be performed to check for any limiting layers in accordance with the Administrative Rules of South Dakota (ARSD) § 74:53:01:30.
- The individual that installs the wastewater system shall be certified in accordance with ARSD § 74:53:02:02.
- All setback conditions of ARSD § 74:53:01:19 shall be met.

Our review is primarily to determine compliance with the minimum sanitary engineering requirements and does not cover items, such as quality of materials, structural soundness, or electrical and mechanical design features. Approval of the plans and specifications does not in any way release the applicant from the responsibility that the project will be an operable facility when construction is completed.

In accordance with ARSD § 74:53:04:07, the Department of Agriculture and Natural Resources' approval of plans and specifications becomes void two years after the date of approval if construction is not initiated prior to that time. Upon request of the owner, voided plans and specifications may be submitted for reconsideration.

Jim Housiaux, P.E.
September 2, 2026
Page 2 of 2

The lifetime of this system is dependent upon proper construction and regularly scheduled maintenance. Please feel free to contact this office if you have any questions.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Neal Konda', with a stylized flourish at the end.

Neal Konda, PE, Natural Resources Engineer
Livestock Services Program
(605) 773-4647

cc: Tami Severson, Miner County Planning/Zoning (email)